Simulation and performance evaluation of shunt hybrid power filter using fuzzy logic based non-linear control for power quality improvement

R BALASUBRAMANIAN^{1,*}, R SANKARAN¹ and S PALANI²

¹School of Electrical & Electronics Engineering, SASTRA University, Thanjavur 613401, India

²Department of Electronics & Communication Engineering, Sudharsan Engineering College, Pudukkottai 622501, India
e-mail: rbalu@eee.sastra.edu

MS received 23 June 2016; revised 23 November 2016; accepted 13 January 2017; published 25 July 2017

Abstract. This paper deals with design and simulation of a three-phase shunt hybrid power filter consisting of a pair of 5th and 7th selective harmonic elimination passive power filters connected in series with a conventional active power filter with reduced kVA rating. The objective is to enhance the power quality in a distribution network feeding variety of non-linear, time-varying and unbalanced loads. The theory and modelling of the entire power circuit in terms of synchronously rotating reference frame and leading to a non-linear control scheme is presented. This work involves introduction of individual fuzzy logic controllers for d and q axis current control and for voltage regulation of the DC link capacitor. The simulation schematic covering the power and control circuits have been developed taking into account severe harmonic distortion caused by non-linear and unbalanced loads. The effectiveness of the fuzzy logic controller for the compensation of harmonics and reactive power has been verified by successive simulation runs and analysis of the results. The proposed controller is also able to compensate the distortion generated by the voltage- and current-fed non-linear loads, unbalanced and dynamically varying loads. Further, excellent regulation of the DC link voltage is accomplished, which significantly contributes to improvement of power quality.

Keywords. Harmonics; hybrid filter; fuzzy logic; power quality; total harmonic distortion.

1. Introduction

A growing number of non-linear loads in distribution system such as diode rectifiers used in adjustable speed drives, electronic ballast used in fluorescent lamps, welding equipment, arc furnaces and other types of switching loads generate harmonic currents and consequent distortion of system voltages. As a result, the power quality of the distribution system is adversely affected in terms of higher power losses and malfunction of equipment fed from the line. Power factor improvement and reduction of harmonics in the system can be achieved by means of passive filters, active filters or hybridisation of both types. The potentialities and limitations of passive filters, their performance optimisation using particle swarm optimization (PSO) algorithm and the performance improvement of distribution system have been investigated by Das [1], Na He *et al* [2] and Rivas *et al* [3]. As a means of overcoming certain limitations of the passive filter, active filters have been introduced subsequently. An active filter needs a controller to process the system signals, generate a

reference current waveform and insulated gate bipolar transistor (IGBT) gate trigger signals so as to inject the compensation currents at the point of common coupling (PCC). The control algorithm can be structured based on analytical equations up to the reference current generation followed by a set of regulators for processing of current error [4–6]. Since the entire system is characterised by non-linearities and possible parameter variations, a set of fuzzy logic-based proportional integral (PI) controllers for compensation is advantageous instead of classical PI controllers [7–10]. Many of the active filter topologies are marked by high kVA rating, which imply higher complexity and cost. Further, the resulting high DC link voltage for effective compensation of higher-order harmonic currents demands higher voltage rating of the semiconductor switches and reliability issues [4]. These problems have motivated the development of hybrid active power filters for harmonic reduction [11, 12]. The hybrid filter topology generally consists of a shunt configuration comprising a passive and an active compensator in series. Different control algorithms and strategies have been reported by many authors with varying levels of performance regarding supply-side power factor and total harmonic distortion (THD) [13–20]. The active

*For correspondence

filters are capable of directing all the harmonic load current components to the passive filter and thereby eliminate any possibility of resonance in the supply system [13]. One relevant idea that has not garnered much attraction is related to the introduction of fuzzy logic theory-based PI controller in the hybrid compensation scheme for handling the inherently present non-linear control problems.

This paper deals with design and simulation of a hybrid filter for elimination of harmonics in a three-phase distribution network feeding non-linear loads. The configuration of the hybrid filter consists of selective fifth and seventh harmonic elimination passive filter connected in series with active filter and terminated with a capacitor as shown in figure 1. For controlling the active filter, a non-linear control algorithm based on synchronously rotating reference frame is utilised. This yields a reference current waveform and forces injection of harmonic currents, which are defined by a pair of fuzzy logic-based PI controllers. For sustaining the compensator action, it is necessary to regulate the DC link capacitor voltage, which is also carried out using another fuzzy logic controller.

2. General theory of fuzzy control

In cases where the phenomena and the mathematical model are not fully understood or non-linearities are present, application of conventional feedback theory has many limitations. An alternative formulation of the control problem is by using fuzzy logic where linguistic variables are used to replace analytical terms in the mathematical model. In general, the FLC consists of three stages: fuzzification, inference

Figure 2. Structure of the fuzzy logic controller.

with rule base and defuzzification [9], as shown in figure 2. During the fuzzification, the numerical input variables are converted into equivalent linguistic variables as fuzzy sets. Then, the input fuzzy sets are sent to the inference mechanism to obtain output fuzzy sets based on the fuzzy rule base table. Finally, the output fuzzy sets are converted into crisp variables as the output, which represents the actuating signal.

3. Power and filter circuits

Figure 1 shows a three-phase distribution circuit feeding a set of non-linear loads, which require power factor and harmonic compensation. The compensator configuration consists of a passive part made up of parallel connected 5th and 7th selective harmonic elimination branches in series with a low rating active power filter provided with a DC link capacitor, the whole compensator being wired in the form of a shunt hybrid power filter. The mathematical model of the whole circuit has been developed for formulating the non-linear control problem and is presented next.

Figure 1. Configuration of shunt hybrid power filter.

3.1 Shunt hybrid power filter modelling

By applying Kirchhoff's laws in figure 1, the equivalent equation governing all the three phases in generic form is obtained [10, 20] as follows:

$$V_{sk} = L_{PFeq} \frac{di_{fk}}{dt} + R_{PFeq} i_{fk} + \frac{1}{C_{PFeq}} \int i_{fk} dt + V_{kM} + V_{MN} \quad (1)$$

where i_{fk} is the filter current, $k = 1, 2, 3$ represent the three phases and R_{PFeq} , L_{PFeq} and C_{PFeq} are equivalent parameter values of the 5th and 7th selective harmonic filters. V_{MN} represents the voltage between the active filter and supply neutral.

The capacitor current I_{dc} and voltage V_{dc} are related by

$$\frac{dV_{dc}}{dt} = \frac{1}{C_{dc}} i_{dc} \quad (2)$$

Assuming balanced supply voltage, we get

$$V_{s1} + V_{s2} + V_{s3} = 0$$

Considering Eq. (1) for $k = 1, 2$ and 3 and adding we get

$$V_{MN} = -\frac{1}{3} \sum_{k=1}^3 V_{kM} \quad (3)$$

The switching function C_k of the k th leg of the inverter [13] is defined as in (4), where S_k and S'_k are the switches in the same leg.

$$C_k = \begin{cases} 1 & \text{if } S_k \text{ is On and } S'_k \text{ is Off} \\ 0 & \text{if } S_k \text{ is Off and } S'_k \text{ is On} \end{cases} \quad (4)$$

Thus, with $V_{kM} = C_k V_{dc}$ and differentiation of the same leads to

$$\frac{dV_{kM}}{dt} = C_k \frac{dV_{dc}}{dt}.$$

By combining Eqs. (1), (3) and (4) and incorporating switching function C_k , the following equations are obtained:

$$\begin{aligned} \frac{dV_{sk}}{dt} &= L_{PFeq} \frac{d^2 i_{fk}}{dt^2} + R_{PFeq} \frac{di_{fk}}{dt} + \frac{1}{C_{PFeq}} i_{fk} \\ &\quad + \left(C_k - \sum_{m=1}^3 C_m \right) \frac{dV_{dc}}{dt} \\ \frac{d^2 i_{fk}}{dt^2} &= -\frac{R_{PFeq}}{L_{PFeq}} \frac{di_{fk}}{dt} - \frac{1}{C_{PFeq} L_{PFeq}} i_{fk} \\ &\quad - \frac{1}{L_{PFeq}} \left(C_k - \frac{1}{3} \sum_{m=1}^3 C_m \right) \frac{dV_{dc}}{dt} + \frac{1}{L_{PFeq}} \frac{dV_{dc}}{dt} \end{aligned} \quad (5)$$

Defining q_{nk} as an overall switching function, it is obtained as

$$q_{nk} = \left(C_k - \frac{1}{3} \sum_{m=1}^3 C_m \right)_n$$

where $n = 0$ or 1 and the value of q_{nk} relies on the phase k and switching function. In other words, the transformation given below depends on the parameters C_1, C_2, C_3 [14, 20] and indicates the interaction among the three phases.

$$\begin{bmatrix} q_{n1} \\ q_{n2} \\ q_{n3} \end{bmatrix} = \frac{1}{3} \begin{bmatrix} 2 & -1 & -1 \\ -1 & 2 & -1 \\ -1 & -1 & 2 \end{bmatrix} \begin{bmatrix} C_1 \\ C_2 \\ C_3 \end{bmatrix} \quad (6)$$

Re-writing Eq. (2) in terms of a switching function k and filter current i_{fk} we get

$$\frac{dV_{dc}}{dt} = \frac{1}{C_{dc}} \sum_{k=1}^3 q_{nk} i_{fk} = \frac{1}{C_{dc}} [q_{n123}]^T [i_{f123}] \quad (7)$$

Since zero-sequence component of the filter current is absent, i_{f3} can be expressed by

$$i_{f3} = -(i_{f1} + i_{f2})$$

A similar substitution of the variable q_n enables the modelling of the capacitor operation as

$$\frac{dV_{dc}}{dt} = \frac{1}{C_{dc}} [2q_{n1} + q_{n2}] i_{f1} + \frac{1}{C_{dc}} [q_{n1} + 2q_{n2}] i_{f2} \quad (8)$$

The entire model of the shunt hybrid power filter in abc reference frame is represented by the following equations:

$$L_{PFeq} \frac{d^2 i_{f1}}{dt^2} = -R_{PFeq} \frac{di_{f1}}{dt} - \frac{1}{C_{PFeq}} i_{f1} - q_{n1} \frac{dV_{dc}}{dt} + \frac{dV_{s1}}{dt} \quad (9)$$

$$L_{PFeq} \frac{d^2 i_{f2}}{dt^2} = -R_{PFeq} \frac{di_{f2}}{dt} - \frac{1}{C_{PFeq}} i_{f2} - q_{n2} \frac{dV_{dc}}{dt} + \frac{dV_{s2}}{dt} \quad (10)$$

$$C_{dc} \frac{dV_{dc}}{dt} = [2q_{n1} + q_{n2}] i_{f1} + [q_{n1} + 2q_{n2}] i_{f2} \quad (11)$$

3.2 Equations in d - q frame

Equations (9)–(11) describing the system model are transformed into the synchronous orthogonal frame using the transformation matrix [14]

$$T_{dq}^{123} = \sqrt{\frac{2}{3}} \begin{bmatrix} \cos \theta & \cos(\theta - 2\pi/3) & \cos(\theta - 4\pi/3) \\ -\sin \theta & -\sin(\theta - 2\pi/3) & -\sin(\theta - 4\pi/3) \end{bmatrix} \quad (12)$$

where $\theta = \omega t$ and ω represents the mains frequency in rad/s.

Equation (7), after transformation, takes the following form:

$$\begin{aligned} \frac{dV_{dc}}{dt} &= \frac{1}{C_{dc}} \left(T_{dq}^{123} [q_{ndq}] \right)^T \left(T_{dq}^{123} [i_{dq}] \right) \\ &= \frac{1}{C_{dc}} [q_{ndq}] [i_{dq}] \end{aligned} \quad (13)$$

On the other hand, Eqs. (9) and (10) are combined and written as

$$\begin{aligned} \frac{d^2}{dt^2} [i_{f12}] &= -\frac{R_{PFeq}}{L_{PFeq}} \frac{d}{dt} [i_{f12}] - \frac{1}{C_{PFeq} L_{PFeq}} [i_{f12}] \\ &\quad - \frac{1}{L_{PFeq}} [q_{n12}] \frac{dV_{dc}}{dt} + \frac{1}{L_{PFeq}} \frac{d}{dt} [V_{s12}] \end{aligned} \quad (14)$$

The aforementioned transformations when applied to Eq. (14) yields

$$\begin{aligned} \frac{d^2}{dt^2} [T_{12}^{dq} [i_{dq}]] &= -\frac{R_{PFeq}}{L_{PFeq}} \frac{d}{dt} [T_{12}^{dq} [i_{dq}]] \\ &\quad - \frac{1}{C_{PFeq} L_{PFeq}} T_{12}^{dq} [i_{dq}] \\ &\quad - \frac{1}{L_{PFeq}} T_{12}^{dq} [q_{ndq}] \frac{dV_{dc}}{dt} \\ &\quad + \frac{1}{L_{PFeq}} \frac{d}{dt} [T_{12}^{dq} [V_{dq}]] \end{aligned} \quad (15)$$

After simplification and reduction of Eq. (15) the following relation is obtained.

$$\begin{aligned} T_{12}^{dq} \frac{d^2}{dt^2} [i_{dq}] &+ \left(\frac{d}{dt} T_{12}^{dq} \right) \frac{d}{dt} [i_{dq}] + \left(\frac{d}{dt} T_{12}^{dq} \right) \frac{d}{dt} [i_{dq}] \\ &+ \left(\frac{d^2}{dt^2} [T_{12}^{dq}] \right) [i_{dq}] = -\frac{R_{PFeq}}{L_{PFeq}} \frac{d}{dt} [T_{12}^{dq} [i_{dq}]] \\ &\quad - \frac{1}{C_{PFeq} L_{PFeq}} T_{12}^{dq} [i_{dq}] - \frac{1}{L_{PFeq}} T_{12}^{dq} [q_{ndq}] \frac{dV_{dc}}{dt} \\ &\quad + \frac{1}{L_{PFeq}} \frac{d}{dt} [T_{12}^{dq} [V_{dq}]] \end{aligned} \quad (16)$$

Further simplification of (16) leads to the following equation in d - q frame of reference.

$$\begin{aligned} \frac{d^2}{dt^2} [i_{dq}] &= - \begin{bmatrix} \frac{R_{PFeq}}{L_{PFeq}} & -2\omega \\ 2\omega & \frac{R_{PFeq}}{L_{PFeq}} \end{bmatrix} \frac{d}{dt} [i_{dq}] \\ &\quad - \begin{bmatrix} -\omega^2 + \frac{1}{C_{PFeq} L_{PFeq}} & -\omega \frac{R_{PFeq}}{L_{PFeq}} \\ \omega \frac{R_{PFeq}}{L_{PFeq}} & -\omega^2 + \frac{1}{C_{PFeq} L_{PFeq}} \end{bmatrix} [i_{dq}] \\ &\quad - \frac{1}{L_{PFeq}} [q_{ndq}] \frac{dV_{dc}}{dt} + \frac{1}{L_{PFeq}} \frac{d}{dt} [V_{dq}] + \frac{1}{L_{PFeq}} \begin{bmatrix} 0 & -\omega \\ \omega & 0 \end{bmatrix} [V_{dq}] \end{aligned} \quad (17)$$

The complete d - q frame dynamic model of the system is obtained from Eqs. (13) and (17) and takes the following form:

$$\begin{aligned} L_{PFeq} \frac{d^2 i_d}{dt^2} &= -R_{PFeq} \frac{di_d}{dt} + 2\omega L_{PFeq} \frac{di_q}{dt} \\ &\quad - \left(-\omega^2 L_{PFeq} + \frac{1}{C_{PFeq}} \right) i_d + \omega R_{PFeq} i_q \\ &\quad - q_{nd} \frac{dV_{dc}}{dt} + \frac{dV_d}{dt} - \omega V_q \end{aligned} \quad (18)$$

$$\begin{aligned} L_{PFeq} \frac{d^2 i_q}{dt^2} &= -R_{PFeq} \frac{di_q}{dt} - 2\omega L_{PFeq} \frac{di_d}{dt} \\ &\quad - \left(-\omega^2 L_{PFeq} + \frac{1}{C_{PFeq}} \right) i_q - \omega R_{PFeq} i_d \\ &\quad - q_{nq} \frac{dV_{dc}}{dt} + \frac{dV_q}{dt} + \omega V_d \end{aligned} \quad (19)$$

$$C_{dc} \frac{dV_{dc}}{dt} = q_{nd} i_d + q_{nq} i_q \quad (20)$$

3.3 Control of harmonic currents

Based on the load and compensator models presented in sections 3.1 and 3.2, the control problem is formulated with the objective of minimising supply-side harmonic currents and improving the power factor. In addition, for maintaining the performance during load fluctuations it is also necessary to maintain a desired voltage across the DC link capacitor. The control law is derived using the following approach.

Re-arranging Eqs. (18) and (19), the control variables u_d and u_q are written as

$$u_d = 2\omega L_{PFeq} \frac{di_q}{dt} + \omega R_{PFeq} i_q - q_{nd} \frac{dV_{dc}}{dt} + \frac{dV_d}{dt} - \omega V_q \quad (21)$$

$$u_q = -2\omega L_{PFeq} \frac{di_d}{dt} - \omega R_{PFeq} i_d - q_{nq} \frac{dV_{dc}}{dt} + \frac{dV_q}{dt} + \omega V_d \quad (22)$$

Processing the current harmonics in terms of the decoupled i_d - i_q components and generating the respective errors along with their derivatives, the required inputs to the fuzzy logic controller are obtained. The idea is to dynamically update the PI controller parameters by the process of fuzzification, inference mechanism and defuzzification. The pair of equations relating the control variables u_d and u_q with d - q axis variables i_d and i_q now take the following form:

$$u_d = L_{PFeq} \frac{d^2 i_d}{dt^2} + R_{PFeq} \frac{di_d}{dt} + \left(-\omega^2 L_{PFeq} + \frac{1}{C_{PFeq}} \right) i_d \quad (23)$$

$$u_q = L_{PFeq} \frac{d^2 i_q}{dt^2} + R_{PFeq} \frac{di_q}{dt} + \left(-\omega^2 L_{PFeq} + \frac{1}{C_{PFeq}} \right) i_q \quad (24)$$

By taking the Laplace Transform of (23) and (24), the transfer function is obtained.

$$\frac{I_d(s)}{U_d(s)} = \frac{I_q(s)}{U_q(s)} = \frac{1}{L_{PFeq} \left(s^2 + \frac{R_{PFeq}}{L_{PFeq}} s + \frac{1}{C_{PFeq} L_{PFeq}} - \omega^2 \right)} \quad (25)$$

Re-arranging Eqs. (21) and (22) for expressing the variables q_{nd} and q_{nq} in terms of the other system variables, the following two equations are obtained:

$$q_{nd} = \frac{2\omega L_{PFeq} \frac{di_q}{dt} + \omega R_{PFeq} i_q + \frac{dV_d}{dt} - \omega V_q - u_d}{\frac{dV_{dc}}{dt}} \quad (26)$$

$$q_{nq} = \frac{-2\omega L_{PFeq} \frac{di_d}{dt} + \omega R_{PFeq} i_d + \frac{dV_d}{dt} - \omega V_d - u_q}{\frac{dV_{dc}}{dt}} \quad (27)$$

Equations (26) and (27) are interpreted as defining control laws for compensation.

3.4 DC link voltage control

In a hybrid compensation technique, switching loss in active power filter is directly proportional to the DC link voltage, and regulation of this voltage is required for effective operation [13, 20, 21]. An additional fuzzy logic-based PI controller is used to regulate the DC link capacitor voltage. The electrical quantity adjusted by this designed voltage regulator is i_{q1}^* .

Focusing on the reactive component i_q for charging the link capacitor, the governing Eq. (20) takes the following form:

$$C_{dc} \frac{dV_{dc}}{dt} = q_{nq} i_q \quad (28)$$

Defining the input equivalent voltage as

$$u_{dc} = q_{nq} i_q.$$

The active filter reactive current is given by

$$i_q = \frac{u_{dc}}{q_{nq}} = \frac{u_{dc} V_{dc}}{q_{nq} V_{dc}} \quad (29)$$

Under normal operating conditions of active filter, the voltage V_{Mq} called q axes voltage of the active filter takes the form $V_{Mq} \cong q_{nq} V_{dc}$ [20].

$$V_{Mq} = -Z_{PFeq1} i_{q1}^* \quad (30)$$

where Z_{PFeq1} is the equivalent impedance of the passive filter for fundamental frequency and its DC component is i_{q1}^*

Now the DC loop control law is deduced from (29) and (30) as

$$i_{q1}^* = \frac{V_{dc}}{-Z_{PFeq1}} u_{dc} \quad (31)$$

The filter current in three phases are expressed as [13]

$$\begin{bmatrix} i_{f1} \\ i_{f2} \\ i_{f3} \end{bmatrix} = \sqrt{\frac{2}{3}} i_q \begin{bmatrix} -\sin \theta \\ -\sin \left(\theta - \frac{2\pi}{3} \right) \\ -\sin \left(\theta - \frac{4\pi}{3} \right) \end{bmatrix} \quad (32)$$

The rms value of the fundamental component of the filter current i_f is given by

$$i_f = \frac{i_q}{\sqrt{3}} \quad (33)$$

Substitution of Eq. (33) into (31) yields the Laplace transformed control law as

$$I_{q1}^*(s) = \frac{V_{dc}(s)}{\sqrt{3} Z_{PFeq1} I_f(s)} U_{dc}(s) \quad (34)$$

To keep the DC link voltage close to the reference value, the error voltage $\tilde{V}_{dc} = V_{dc}^* - V_{dc}$ is processed by a fuzzy logic controller. The aforementioned power circuit along with the compensator has to be interfaced with an appropriate controller for generating gate trigger waveforms for the IGBTs of the active filter. This will minimise the harmonic currents drawn from the mains and also for sustaining the DC link voltage across capacitor through a regulator action. In view of inherent non-linearities present in the system and the possibility of fluctuation of source voltage and/or loading pattern, a heuristic controller based on fuzzy logic theory is appropriate.

4. Development of fuzzy logic controller

Essentially, the control action has to be incorporated in the d - q axes current loops and the capacitor voltage regulator loop. The requirement of injecting compensating harmonic currents has to be implemented by separating the load side harmonic currents in comparison with the filter current to generate three error channels, one each for I_d , I_q and V_{dc} as shown in figure 3. Accordingly, there are three channels of control action for handling a corresponding three numbers of error signals and their derivatives. Considering the error and its rate of change as fuzzy variables, their processing is carried out using fuzzy logic controller in order to dynamically vary the K_P and K_I parameters [8].

Figure 4 shows the structure of the control scheme, which consists of blocks for d - q axes transformation, reference current generation using non-linear control law along with the elements of fuzzy-based PI control scheme. Essentially, this scheme generates a set of IGBT gate trigger signals for 6 pulse voltage-fed inverter for realising the compensator action in the power circuit.

Table 1. Fuzzy rule base for current control loop.

Δe	e				
	NB	NS	Z	PS	PB
NB	NB	NB	NB	NS	Z
NS	NB	NS	NS	Z	PS
Z	NB	NS	Z	PS	PB
PS	NS	Z	PS	PB	PB
PB	NS	NS	PS	PB	PB

e is the error; Δe is the derivative of error; NB is the negative big; NS is the negative small; Z is the zero; PS is the positive small; PB is the positive big.

Table 2. Fuzzy set rules for voltage control loop.

Δe	e						
	NB	NM	NS	Z	PS	PM	PB
NB	NB	NB	NM	NM	NM	NS	Z
NM	NB	NB	NB	NM	NS	Z	PS
NS	NB	NB	NM	NS	Z	PS	PM
Z	NB	NM	NS	Z	PS	PM	PB
PS	NM	NS	Z	PS	PS	PM	PB
PM	NS	Z	PS	PM	PM	PM	PB
PB	NS	NM	NS	PS	PM	PM	PB

e is the error; Δe is the derivative of error; NB is the negative big; NM is the negative medium; NS is the negative small; Z is the zero; PS is the positive small; PM is the positive medium; PB is the positive big.

Table 3. Specification of parameters.

Parameters	Values
Phase voltage and frequency	$V_{\text{rms}} = 230 \text{ V}$ and $f_s = 50 \text{ Hz}$
Line impedance	$R_s = 0.1 \Omega$, $L_s = 4 \text{ mH}$
Current source type non-linear load	$R_L = 50 \Omega$, $L_L = 10 \text{ mH}$
Voltage source type non-linear load	$R_L = 36 \Omega$, $C_L = 1000 \mu\text{F}$
DC link voltage of compensator and capacitance	$V_{\text{dc}} = 25 \text{ V}$, $C_{\text{dc}} = 6600 \mu\text{F}$

5.1 Current source type non-linear load

The three-phase main supplies a diode bridge rectifier feeding an R - L load, which imposes a typical flat top non-linearity in the current waveform, resulting in pronounced harmonic at the supply side. The hybrid compensator with non-linear control algorithm using fuzzy logic-based PI controller is introduced to mitigate the above situation. The simulation results at steady state of the proposed hybrid power filter with the above load are presented in figure 5a

Figure 5. Steady-state response of shunt hybrid filter for current source type non-linear load.

to e covering the waveforms of three-phase source voltage (V_{S123}), load current (I_{L123}), source current (I_{S123}) after compensation, filter current (I_{F123}) and DC link voltage (V_{dc}), respectively.

Figure 6a and b shows the harmonics spectrum of supply current before compensation and after compensation, respectively. The results indicate that the THD of the source current of phase 1 is reduced from 25.74% to 3.43% due to the introduction of the shunt hybrid filter. The shunt hybrid filter is found to be effective in handling the compensation requirements of the entire set of load variations.

5.2 Dynamically varying R - L load

It is quite common that the load currents handled by a distribution feeder vary widely over the time of the day. Hence it is desirable that the filter is able to handle dynamically varying load conditions with appropriate correction. The simulation results for dynamic change of load current from 11 A(rms) to 17.9 A at $t = 2 \text{ s}$, are presented in figure 7a to e covering source voltage (V_{S123}), load current (I_{L123}), source current (I_{S123}), filter current (I_{F123}) and DC link voltage waveforms, respectively. Fuzzy-based controller designed for this application maintains a low level of THD at the source end along with effective regulation of the DC link voltage. Further, the indirect effect of harmonic correction for power factor improvement has also been investigated in the case of R - L load and the simulations results pertaining to the

Figure 6. Harmonic spectrum of source current in phase 1 (a) without filter, (b) with filter.

Figure 7. Response of shunt hybrid filter for dynamic variation in current source type non-linear load.

same are shown in figure 8. The results show that the source side power factor comes closer to unity under varying load conditions.

Figure 8. Phase voltage and current waveforms under dynamic variation in current source type non-linear load.

Figure 9. Response of shunt hybrid filter for voltage source type non-linear load.

5.3 Voltage source type non-linear load

Many appliances, such as UPS and motor drives, connected to a distribution line have in-built rectifiers terminated with high-value capacitors. Such a load draws high values of spike currents of opposite polarity in every cycle of the mains and is incorporated in the simulation schematic for examining the filter performance. The simulation results corresponding to this case study is presented in figure 9a to e, which show the source voltage (V_{S123}), load current (I_{L123}), supply current (I_{S123}) after compensation, filter current (I_{F123}) and DC link voltage (V_{dc}) waveforms, respectively. Figure 10a and b show the harmonic spectrum of line currents from mains before and after filtering, which indicates that the THD of the source current is considerably reduced from 29.55% to 4.08%.

Figure 10. Harmonic spectrum of source current in phase 1 (a) without filter, (b) with filter.

Figure 11. Performance of the shunt hybrid filter under varying R-C load condition.

5.4 Dynamically varying R-C load

By introducing a step increase in load current to the extent of doubling the rms value of the R-C circuit, the ability of

Figure 12. Performance of shunt hybrid filter in unbalanced load condition.

the hybrid filter to mitigate the harmonic current dynamically is examined in the simulation setup. The results of this simulation, where the load current changes from 15.95 A (rms) to 29.32 A at 2 s are shown in figure 11a to e. It is seen that the designed hybrid filter reduces the harmonic content within a THD of 5%, in addition to maintaining a steady DC link voltage.

5.5 Unbalanced load

Distribution networks are characterised by unbalanced phase currents and it is necessary to examine the effectiveness of the designed hybrid filter for handling such loads. For simulation, this unbalance is introduced by the parallel connection of a single-phase diode rectifier fed R-L load with $R = 20\Omega$ and $L = 5$ mH in phase 1 only. The steady-state response of the entire system is depicted in figure 12a to e. It is observed from the results that the THD of phase 1 current is 2.05% at the supply side, while the remaining phase current THDs are 4.65% and 4.60%, respectively.

6. Limitations and future scope

Although a three-phase distribution system for power quality enhancement has been considered in this paper, it is limited to a three-wire system only with isolated neutral. Hence, issues arising out of zero-sequence currents due to load unbalance have not been considered. This

research work can be extended for a three-phase four-wire system. Further, incorporation of controllers utilising various other soft computing techniques such as neural, fuzzy-neural and genetic algorithms can also be carried out as further work.

7. Conclusion

The design of hybrid filter along with fuzzy logic-based PI controller is carried out by formulating the non-linear control scheme with synchronously rotating reference frame theory-based reference current generation. The overall system is simulated using power system block set of MATLAB SIMULINK software for different types of non-linear loads. The steady-state response of the proposed filter for current source type non-linear load and for a step load disturbance shows that the source current is sinusoidal after compensation and DC link voltage is also maintained constant. The Fourier analysis indicates that the THD has been reduced to 3.43%. The phase voltage and current waveform depict that the power factor is maintained around 0.9. Similar results have been obtained when the supply system feeds RC-type non-linear loads. Finally, the ability of the hybrid compensator for handling unbalanced loads with improved power quality of the distribution system is presented. Further, it is observed that in all the aforementioned load conditions, the source currents are maintained nearly sinusoidal and also in phase with the respective system voltages. Furthermore, the THD has been brought down to well within 5% as stipulated by IEEE 519-1992 standard in all the above cases. Thus, the introduction of fuzzy logic-based PI controller is capable of suppressing the harmonics present in the supply currents and improves the source side power factor. Incidentally, on account of lower DC link voltage, the rating of the active power filter used in hybrid scheme is considerably reduced.

References

- [1] Das J C 2004 Passive filters—potentialities and limitations. *IEEE Trans. Ind. Appl.* 40(1): 232–241
- [2] Na He, Dianguo Xu and Lina Huang 2009 The application of particle swarm optimization to passive and hybrid active power filter design. *IEEE Trans. Ind. Electron.* 56(8): 2841–2851
- [3] Darwin Rivas, Luis Moran, Juan W Dixon and Jose R Espinoza 2003 Improving passive filter compensation performance with active techniques. *IEEE Trans. Ind. Electron.* 50(1): 161–170
- [4] Karuppan P and Mahapatra K K 2014 Active harmonic current compensation to enhance power quality. *Int. J. Electr. Power Energy Syst.* 62: 144–151
- [5] Buso S, Malesani L and Mattavelli P 1998 Comparison of current control techniques for active power filter applications. *IEEE Trans. Ind. Electron.* 45(5): 722–729
- [6] An Luo, Zhikang Shuai, Wenji Zhu and Jhon Shen Z 2009 Combined system for harmonic suppression and reactive power compensation. *IEEE Trans. Ind. Electron.* 56(2): 418–428
- [7] Merih Palandoken, Murat Aksoy and Mehmet Tumay 2004 Application of fuzzy logic controllers to active power filters. *Electr. Eng.* 86(4): 191–198
- [8] Palandoken M, Aksoy M and Tumay M 2003 A fuzzy-controlled single-phase active power filter operating with fixed switching frequency for reactive power and current harmonics compensation. *Electr. Eng.* 86(1): 9–16
- [9] Mikkili S and Panda A K 2012 Real-time implementation of PI and fuzzy logic controllers based shunt active filter control strategies for power quality improvement. *Int. J. Electr. Power Energy Syst.* 43: 1114–1126
- [10] Panda A K and Mikili S 2013 FLC based shunt active filter (p-q and Id-Iq) control strategies for mitigation of harmonics with different fuzzy MFs using MATLAB and real-time digital simulator. *Int. J. Electr. Power Energy Syst.* 47: 313–336
- [11] Srianthumrong S and Akagi H 2003 A medium-voltage transformer less AC/DC power conversion system consisting of a diode rectifier and a shunt hybrid filter. *IEEE Trans. Ind. Appl.* 39(3): 874–882
- [12] Singh B, Verma V, Chandra A and Al-Haddad K 2005 Hybrid filters for power quality improvement. *IEEE Proc-Gener. Transm. Distrib.* 152(3): 365–378
- [13] Rahmani S, Hamadi A, Mendalek N and Al-Haddad K 2009 A new control technique for three-phase shunt hybrid power filter. *IEEE Trans. Ind. Electron.* 56(8): 2904–2915
- [14] Rahmani S, Hamadi A and Al-Haddad K 2012 A Lyapunov-function-based control for a three-phase shunt hybrid active filter. *IEEE Trans. Ind. Electron.* 59(3): 1418–1429
- [15] Mishra S and Kumar Ray P 2016 Nonlinear modeling and control of a photovoltaic fed improved hybrid DSTATCOM for power quality improvement. *Int. J. Electr. Power Energy Syst.* 75: 245–254
- [16] Salmeron P and Litran S P 2010 A control strategy for hybrid power filters to compensate four-wire three-phase systems. *IEEE Trans. Power Electron.* 25(7): 1923–1931
- [17] Lam C S, Wong M C and Han Y D 2012 Hysteresis current control of hybrid active power filters. *IET Power Electron.* 5(7): 1175–1187
- [18] Unnikrishnan A K, Chandira Sekaran E, Subhash Joshi T G, Manju A S and Aby Joseph 2015 Shunt hybrid active power filter for harmonic mitigation: a practical design approach. *Sadhana* 40(4): 1257–1272
- [19] Chandan Kumar and Mishra M K 2014 An improved hybrid DSTATCOM topology to compensate reactive and nonlinear loads. *IEEE Trans. Ind. Electron.* 61(12): 6517–6527
- [20] Rahmani S, Hamadi A, Al-Haddad K and Dessaint L A 2014 A combination of shunt hybrid power filter and thyristor-controlled reactor for power quality. *IEEE Trans. Ind. Electron.* 61(5): 2152–2164
- [21] Wai-Hei Choi, Chi-Seng Lam, Man-Chung Wong and Ying-Duo Han 2013 Analysis of DC-link voltage controls in three-phase four-wire hybrid active power filters. *IEEE Trans. Power Electron.* 28(5): 2180–2191